(10-09-01)

	Construction Contractor Daily Use Checklist			
Requirement	for LADDERS	YES	NO	NA
1910.25	Are ladders used with safety feet?			
1910.26(b)	Are ladders free from sharp edges and splinters?			
1910.25(b)(2)	Are stepladders under 20' in length?			
1926.1053	Are extension ladders tied off or held while being used?			
1926.951	Are metal ladders restricted from use near electrical work?			
1926.1053	Do movable parts of ladders operate freely without binding or undue play?			
1926.1053	Is there a locking device to hold the ladder in the open position?			
1926.1053(b)	Does the ladder side rails extend at least 3 feet above the upper landing surface?			
1926.1060	Have employees been trained in identifying hazards related to ladders, correct use of ladders, maximum load capacity, and correct method of ascending or descending a ladder?			
Supervisor Signature:PO#/FWR# Date				
Company: Comments:				